

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J	PAGE OF PAGES 1 5
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 12-Jun-2019	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC MID ATLANTIC ACQUISITION CORE 9324 VIRGINIA AVENUE NORFOLK VA 23511-3095		CODE N40085	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X	9A. AMENDMENT OF SOLICITATION NO. N4008519R9106
				X	9B. DATED (SEE ITEM 11) 20-May-2019
					10A. MOD. OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACT ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of amendment 0002 is to issue the responses to PFI Questions: Proposals are due 20 June 2019 at 2:00pm EST. Please see continuation page.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)			BY _____ (Signature of Contracting Officer)		11-Jun-2019

#	Date	Reference			Question	Answer	Amendment #
		Page	Section	Para			
1	05/22/19	33	00 21 00	(i)	Project estimate is \$5,000,000-\$10,000,000 but you are asking for project experience of \$10,000,000 or greater, will you take \$5,000,000 or greater experience examples?	Factor 1, Corporate Experience: (i) Size: has been changed from "\$10,000,000,or greater" to "\$5,000,000 or greater."	1
2	05/22/19	25	52.23 6-27	3	Does Camp Lejeune or New River DBIDs get you on the Stone Bay plus submitting name for site visit?	Please refer to the site visit clause 52.236-27 regarding instructions on accessing the base or contact the POC listed for the site visit.	1
3	05/23/19	32 - 33	00 21 00	1.2.2 (B)Factor 1	This inquiry and request is in regards to the relevant project guidelines established in this RFP and as indicated in Factor 1, Corporate Experience. The project is advertised as a Total small business set-aside with an estimated range of \$5 - 10 million. We believe the minimum relevant project value of \$10 million is excessive as well as isolating experience to either gymnasium or physical fitness facilities. Most small businesses do not have the single project experience of this range yet do have the experience in successfully constructing similar structures. In this instance the determination of physical fitness facility is more in regards to finishes than	Factor 1, Corporate Experience: (i) Size: has been changed from "\$10,000,000,or greater" to "\$5,000,000 or greater."	1

					the actual structure and components. Would the government be open to decreasing the minimum contract dollar value and the scope/ complexity to new construction of a pre-engineered metal building or similar structure.		
4	05/30/19		22 00 00	2.2	1. Specification Section 22 00 00 – 2.2 says PVC pipe shall contain a minimum of 80 percent recycled content. There has never been PVC pipe with 80 percent recycled content. Charlotte Pipe used to produce pipe with 25 percent recycled material. However, they have recently discontinued the production of PVC pipe with recycled content. Our suppliers are not aware of any other pipe supplier that makes this type of pipe. Will standard PVC be allowed or does the Government have knowledge of an alternate supplier of recycled PVC pipe?	Standard PVC solid core sanitary drain, waste, vent piping (DWV) with no recycled content is acceptable.	1

5	05/30/19		Drawi ng P102	Draw ing P104	1. Drawing P-102 and P-104 appear to show new water and sewage running to two Hi-Lo Water Coolers (P-1). However, it only shows the symbol P-1 on one of the Water Coolers. Is one existing-to-remain or do we need to provide two P-1's?	The water cooler P-1 is a Hi-Lo water cooler with 2 bubblers and 2 catch basins. One is set at standard height and the other is set for ADA compliance. This is provided as one unit assembly by the manufacturer. This is all described in specification section 22 00 00 PLUMBING, GENERAL PURPOSE. There is an existing HI-Lo water cooler in the existing building located in the corridor 129 that is to be replaced. This is indicated on drawing I-700. See demo note 7 and new work note 8 on that drawing.	1
6			Drawi ng P601	P104	1. The Fixture Schedule on drawing P-601 shows two Back Flow Preventers (BFP-1 and BFP-2). The drawings only show one Back Flow Preventer being used on drawing P-104. Please clarify.	As indicated on the fixture schedule on drawing P-601, BFP-1 is for boiler make-up water and is located in mechanical room A103 and is shown on drawing P-104. BFP-2 is for chiller make-up water and is located in the existing mechanical room 128. it is located in the domestic water line connection to AS-1 shown on the mechanical drawings	1
7	06/04/19		1	SF14 42	Please accept this request to extend the bid date two weeks from the original published date of	No proposal extension will be granted at this time.	

					20, June 2019		
8				Information Transport System	Basket Tray Height: At what height will the basket tray be installed in the exercise area?	16 ft Above finished floor	
9				Information Transport System	CCTV Cameras: Please can you confirm the quantity of Category 6 cables to be installed to each CCTV camera?	2	
10				Information Transport System	TV Locations: Please can you confirm the following for each TV location? <ul style="list-style-type: none"> • The quantity of Category 6 cables to be installed to each TV location. • Is an RG-6 Coaxial cable required to the TV locations? 	2, Yes RG-6 is required.	
11			M602		Note #1 under the Existing Rooftop Unit (RFI) schedule on drawing M-602 asks us to replace hot water coils of the existing Rooftop Units. The roof was not accessible during the site-visit. The schedule includes the make and model of the existing RTU's but these models are semi-custom with a wide range of options and dimensions. Can the government please provide the serial numbers to the two existing McQuay RTU's so direct replacement coils can be provided?	Sheet M-602, Existing Rooftop Unit Schedule, add the following footnote: "3. U-RTU-1 Serial # FBOU090701462, U-RTU-2 Serial # FBOU090701538"	

12					Can the site visit sign in sheet be provided to the participants?	Provided in Amendment 1.	
13					Please consider extending the bid date	No proposal extension will be granted at this time.	
14	06/11/19	14	3300	2.3.1.3	in the 3300 spec section starting on page 14 and ending on page 15 the section 2.3.1.3 (g,h) for Slab On Grade shows both a Synthetic Micro Fiber & a Synthetic Macro Fiber, however neither shows any details such as dosage rates or lengths.	Not required as welded wire reinforcing (6X6-W2.0XW2.0) is provided over vapor retarder and granular base. See note 1 of S-101 sheet.	
15	06/11/19		ES101		1. On sheet ES101 New Work Key Notes #7 and #13 Provide Lighting Fixture Type V1 and S3 I do not see these on the Lighting Fixture Schedule EL 601 or EL602.	Fixtures V1 and S3 are listed in the Exterior Fixture Schedule on sheet EL601.	
16	06/11/19		ES102		1. On sheet ES102 New Work Key Notes #3 and #4 Provide Lighting Fixture S2 and S1 I do not see these on the Lighting Fixture Schedule EL601 or EL602.	Fixtures S2 and S1 are listed in the Exterior Fixture Schedule on sheet EL601.	

(End of Summary of Changes)